



Structural Performance Certification Authorization Report

Pocahontas Aluminum Company, Inc.

PO Box 756, 2001 Industrial Drive
Pocahontas, AR 72455, USA

Certification ID:	757-109
Company Code:	757
Certification Date:	7/25/2013
Revision No:	1
Revision Date:	6/16/2023
Expiration Date:	7/11/2026

Product Rating Information:

Model:	SH46 PVC Single Hung w/Metal Locks			
Operator Type:	H			
Configuration:	EM/IM			
Referenced Standard:	AAMA/WDMA/CSA 101/I.S.2/A440-08			
Product Rating:	Class R-PG40 1016x1600 (40x63)-Type H			
Rated Dimensions:	Max Width:	40 in	Max Height:	63 in

Qualifying Test Information:

Test Report No:	ATI-C8551.02-501-47
Test Report Expiration:	7/11/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaull
2023.06.16 07:37:05
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500




Structural Performance Certification Authorization Report



Revision History

Rev #	Date	Description
0	7/25/2013	Initial Issuance.
1	6/16/2023	Granted 3 Year Extension.

**INSTALLATION METHOD
PVC (VINYL) SH46 SINGLE HUNG
ELEVATION & ANCHOR LAYOUT**



1" FROM CORNERS TYP
TOP & BOTTOM



INSTALLATION ANCHOR

9" MAX TYP

1" FROM CORNERS TYP

9" MAX TYP TOP & BOTTOM

SCALE: NTS
DWN BY: AMM
CHK BY: KEA
DATE: 9/27/13

TITLE:
INSTALLATION METHOD
PVC (VINYL) SH46 SINGLE HUNG
ELEVATION & ANCHOR LAYOUT

PREPARED BY:
POCAHONTAS ALUMINUM COMPANY, INC.
2001 INDUSTRIAL DRIVE
POCAHONTAS, AR 72455
PH: 870-892-3689 FAX: 870-892-9858

REVISIONS			
NO.	DESCRIPTION	BY	DATE

COPYING OR
DUPLICATION IS
PROHIBITED WITHOUT
WRITTEN PERMISSION
FROM POCAHONTAS
ALUMINUM
COMPANY, INC.





Structural Performance Certification Authorization Report

Pocahontas Aluminum Company, Inc.

PO Box 756, 2001 Industrial Drive
Pocahontas, AR 72455, USA

Certification ID:	757-110
Company Code:	757
Certification Date:	7/25/2013
Revision No:	1
Revision Date:	6/16/2023
Expiration Date:	7/11/2026

Product Rating Information:

Model:	SH46 PVC Single Hung w/Metal Locks			
Operator Type:	H			
Configuration:	EM/All			
Referenced Standard:	AAMA/WDMA/CSA 101/I.S.2/A440-08			
Product Rating:	Class R-PG45 1016x1600 (40x63)-Type H Neg DP=50			
Rated Dimensions:	Max Width:	40 in	Max Height:	63 in

Qualifying Test Information:

Test Report No:	ATI-C8551.02-501-47
Test Report Expiration:	7/11/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull
2023.06.16 07:43:37
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500




Structural Performance Certification Authorization Report



Revision History

Rev #	Date	Description
0	7/25/2013	Initial Issuance.
1	6/16/2023	Granted 3 Year Extension.

**INSTALLATION METHOD
PVC (VINYL) SH46 SINGLE HUNG
ELEVATION & ANCHOR LAYOUT**



1" FROM CORNERS TYP
TOP & BOTTOM



INSTALLATION
ANCHOR

9" MAX TYP

1" FROM CORNERS
TYP

9" MAX TYP TOP & BOTTOM

SCALE: NTS

DWN BY: AMM

CHK BY: KEA

DATE: 9/27/13

TITLE:
INSTALLATION METHOD
PVC (VINYL) SH46 SINGLE HUNG
ELEVATION & ANCHOR LAYOUT

PREPARED BY:
POCAHONTAS ALUMINUM COMPANY, INC.
2001 INDUSTRIAL DRIVE
POCAHONTAS, AR 72455
PH: 870-892-3689 FAX: 870-892-9858

REVISIONS

NO.	DESCRIPTION	BY	DATE

COPYING OR
DUPLICATION IS
PROHIBITED WITHOUT
WRITTEN PERMISSION
FROM POCAHONTAS
ALUMINUM
COMPANY, INC.

